

Key

Problem No. 1 (20 pts)

As a process engineer, you determine the following data for one of your projects:

- Land cost - \$ 100,000 two years before start-up
- Construction costs - \$100,000 per year spread evenly over the two years before start-up.
- A lump sum payment for a patent made one year before start-up of \$500,000 is required.
- After tax cash flow (including depreciation) - \$ 1,000,000 / yr for the first five years of project and \$ 600,000 for the sixth year (final) of the project.

Determine: The present worth of the project at 20 % continuous interest.

Problem No. 2 (80 pts)

You are assigned the following project to dispose of a stream of waste acid sludge. You determine the following information and data.

- The stream amounts to 150 tons / day of 15 wt % H₂SO₄. The other 85 wt % is mostly water, but there is sufficient "gunk" to make the stream highly viscous at ambient temperatures. The specific gravity of this stream is 1.1 and its heat capacity is 1.08 BTU/lb F.
- Caustic will be used to neutralize the acid stream.
- A stirred-tank reactor will be used for neutralization. Because of the "gunky" nature of the acid waste, additional agitation will be required. Laboratory tests have indicated a 10 Hp, carbon steel dual-impeller, 50 RPM turbine mixer will be required for each 300 gallons of reactor volume. These agitators are in addition to the normal agitation system which comes with the stirred-tank reactor.

The reactor should be sized to provide a 30 minute retention time based on total feed to the reactor.

- The caustic will be delivered to the project as a 40 % NaOH solution (Sp. Gr = 1.43) in 5,000 gallon tank trucks. Delivery is 8:00 to 5:00 weekdays only, with no night, weekend, or holiday delivery. The caustic is to be off-loaded into a large holding tank.
- The caustic is to be transferred to a reactor feed tank where it is diluted to 20 % NaOH (Sp. Gr. = 1.23) by continuous dilution with water. The dilution tank should provided 1 hour retention and be agitated.
- Laboratory tests have indicated the neutralization reaction will occur more readily if the "gunky" waste acid sludge is heated from its production temperature of 70 F to 120 F before neutralization. Waste steam at 220 F is available, and tests on the material have indicated a heat transfer coefficient of no more than 50 BTU/hr ft² F. The waste acid is at a pressure sufficient to get it through the exchanger and to the reactor without a pump.
- From the reactor the effluent is to be pumped to the waste treatment area of the plant. The treatment area is at the same elevation as the neutralization unit, but is roughly three miles away.
- For the transfer of 40 % caustic from the storage to the dilution tank there are two diaphragm pumps in storage. These are available to the project at no cost.

- The reactor caustic feed pump(s) for feeding the 20 % caustic to the reactor should be diaphragm pump(s) and must be purchased.
- The process must operate round-the-clock, 330 days per year.
- This neutralization unit will be an “add-on” to the existing unit and will not require site preparation, control house, etc.
- Assume carbon steel for all pieces of equipment.

Solution:

1. Generate a flow sheet for the process showing all equipment items with names and numbers.
2. Determine the mass balance for the process showing for each stream the component flows and total flows in lb /hr.
3. Determine the project FCI in late 1998 dollars.

Problem No 1

Given: Land \$100,000 (-2 yrs)
Construction \$200,000 (-2 to 0 yrs)
Patent \$500,000 (-1 yr)
Cash Flow \$1,000,000 yr (0-5 yrs)
\$600,000 yr (6 yr)

Find: PW @ 20%

Land - 100,000 (1.492) = - \$149,200
Const - 100,000 (2) (1.23) = - \$246,000
Patent - 500,000 (1.221) = - \$610,500
CF (1-5) 1,000,000 (5) (0.632) = \$3,160,000
CF (6) 600,000 (0.3334) = \$200,040

NPV =>

\$ 2,354,400

Problem No. 2

Given: Waste Acid 150 Ton/Day @ 15% H₂SO₄

$\rho_{sp} = 1.1, \quad \rho_p = 1.08 \frac{BTU}{lb \cdot F}$

Neutralize in stirred tank reactor
 Add. Agitation 1 10HP 50 RPM / 300 gal

Reactor - 30 minute residence time


Caustic delivered @ 40% NaOH $\rho_{sp} = 1.43$
 in 5000 gal trucks

Caustic diluted to 20% $\rho_{sp} = 1.23$

Heat waste acid from 70°F → 120°F
 with 220°F waste steam. $U = 50 \frac{BTU}{lb \cdot F \cdot ft^2}$

Effluent pumped 3 miles

A) Flow sheet



B) Material Balance


Waste acid stream (5)

$$150 \frac{\text{Ton}}{\text{Day}} \left(2000 \frac{\text{lb}}{\text{Ton}} \right) \left(\frac{1 \text{P}}{24 \text{hr}} \right) = 12,500 \frac{\text{lb}}{\text{hr}}$$

Acid in stream = $12,500 \frac{\text{lb}}{\text{hr}} (0.15) = 1875 \frac{\text{lb}}{\text{hr}}$

Waste Acid [Gunk + H₂O]

$$12,500 (0.85) = 10625 \frac{\text{lb}}{\text{hr}}$$



NaOH Req'd

$$1875 \frac{\text{lb}}{\text{hr}} \left(\frac{80}{98} \right) = 1530 \frac{\text{lb}}{\text{hr}}$$

Na₂SO₄ Produced = $1875 \left(\frac{142}{98} \right) = \underline{\underline{2720 \frac{\text{lb}}{\text{hr}}}}$

H₂O Produced = $1875 \left(\frac{36}{98} \right) = 690 \frac{\text{lb}}{\text{hr}}$

Caustic req'd (40%) = $1530 \left(\frac{1}{0.40} \right) = \underline{\underline{3825 \frac{\text{lb}}{\text{hr}}}}$

- Dilution H₂O -

$$0.20 \text{ (Dilute soln)} = 1530 \frac{\text{lb}}{\text{hr}}$$

$$\frac{1530}{0.20} = \underline{\underline{7650 \frac{\text{lb}}{\text{hr}}}}$$

Dilute H₂O Added = $7650 - 3825 = \underline{\underline{3825 \frac{\text{lb}}{\text{hr}}}}$

Trnk Tracks

Exp 3 pm Friday to 10 AM Tuesday (Holiday on Monday)
 ⇒ 91 HRS

Caustic req'd @ 40%

$$\frac{3825 (91)}{8.33 (1.45)} = 29,200 \text{ gals say } \underline{\underline{30,000 \text{ gals}}}$$

Unload Truck in 50 minutes

$$Flow = \frac{5000}{50} = 100 \text{ GPM}$$

Reactor Discharge H₂O

$$3825(0.60) + 3825 + 10625 + 620 = \underline{\underline{17,435 \text{ lbs}}}$$

From Dilution tank to reactor 20% Caustic

$$NaOH = 1530$$

$$Total = \frac{1530}{0.20} = 7650$$

$$H_2O = 2295 + 3825 = 6120$$

Equipment

P 101A Caustic unloading pump
101B 100 GPM @ 60 ft Head

\$1550
300

Fig 14-40 PS 526
Fig 14-54 PS 523

\$1550
300

T101 Caustic Storage

\$40,000

34,000 gal Fig 14-56
PS 539

P102 A Caustic Transfer
102 B

Available

J102 (Dilution Tank)
Reactor Seed tank

\$10,000

$$5.4 \text{ GPM} + \frac{3825}{833(60)} = 13 \text{ GPM}$$

$$13 \text{ GPM (60 min)} = 780 \text{ gal}$$

say 800 gal

Fig 14-56 PS 539

P 103 A Caustic Feed pump
 103 B 13 GPM Diglycym
 Fig 14-43 PS 528

\$ 3000
 \$ 3000

H 101 Acid Heater

$$Q = 12,500 \frac{lb}{hr} \left(\frac{1.08 \frac{BTU}{lb \cdot F}}{1.08} \right) (120-70) = 675,000 \frac{BTU}{hr}$$

$$\Delta T_{LM} = \frac{(220-120) - (220-70)}{\ln \left(\frac{100}{150} \right)} = 123 \text{ F}$$

$$A = \frac{675,000 \frac{BTU}{hr}}{123 \text{ F} \left(50 \frac{BTU}{hr \cdot ft^2 \cdot F} \right)} = 110 \text{ ft}^2$$

Fig 15-13 PS 616

\$ 4500

P 104 A Effluent Pumps
 104 B

$$\text{Flow} = 13 \text{ GPM} + \frac{12500}{8.33(LI)60}$$

$$13 + 22.7 = 35.7 \text{ GPM}$$

$$\text{Head} = \frac{5280 \text{ ft}}{mi} (3 \text{ mi}) \left(\frac{0.5 \text{ ft Head}}{100 \text{ ft Run}} \right) \approx 80 \text{ ft}$$

Fig 14-40 PS 526
 301p Fig 14-54 PS 533

\$ 1600
 \$ 200

\$ 1600
 \$ 200

R 101 Reactor

Volume 35.7 GPM (30 min) = 1071 gal

\$ 10,500

Agitators $\frac{1071}{300} = 3.57 = 4.0$

Purchase 5 need 4

Fig 14-57 10 Hp \$ 540 \$ 9500 (5)

\$ 47,500

Total Equipment

\$ 125,800

Lang Factor Deliver Install $\frac{1998}{1990}$ (Conting) Lang
125,800 (1.1) (1.05) (1.28) (1.20) (4.74)

= \$ 1.06 mm